



OGS-20 Oxygen Generator

Installation, Operation and Maintenance Manual



Oxygen Generating Systems Intl. (OGSI)

Division of Audubon Machinery Corporation

814 Wurlitzer Drive, North Tonawanda, New York 14120 USA

Tel: (716) 564-5165 **Toll Free:** (800) 414-6474 **Fax:** (716) 564-5173

E-mail: ogsimail@ogsi.com

Website: www.ogsi.com

Part # 9000000.010

US\$ 25.00

Table of Contents

Topic	Page Number
Using this Manual	1
Initial Inspection	2
Warranty Information and Liabilities	3
Safety Guidelines	5-6
➤ Handling	5
➤ Operating	6
Product Information	7-18
➤ Features and Applications	7
➤ PSA Technology	9
➤ Components	10
➤ Process Flow Description	18
➤ Specifications	19
Safety Precautions	20
Pre – Installation	21
Required Operating Conditions	22
Set-up and Installation	23
Operating Instructions	24
Troubleshooting Guide	25
Preventive Maintenance	27
Technical Service Assistance	28
Appendix	I-VII
➤ Spare Parts List	I
➤ Oxygen Cleaning Procedure	III
➤ Air Changes by Room Size	V
➤ Units of Measurement	VI
➤ Maintenance Log	VII

©2010, *OGSI*. All rights reserved. *OGSI* is a registered trademark.
This publication may not be reproduced in part or whole without written permission of *OGSI*.


Using the Manual

This manual is intended as a guide for operators/users of **OGSI** Oxygen Generators and Oxygen Generating Systems. It includes information on our warranty policy, features, functions, applications, proper set-up and installation, operation and preventive maintenance of our products.

The following symbols are used throughout the manual:



Information
(Do not use product before reading the manual)



Sound



No Smoking



No Open Flames



Flow Meter



No Oil



Electrical Hazard



Fire Hazard



Warning



Power ON/OFF



Timer



Not Connected to Outlet



Initial Inspection

The crate should be opened and inspected immediately upon delivery. Unpack the unit at once and perform a visual inspection to determine if it is dented, bent or scratched. Also check to make sure the power cord is attached and that the control panel has not been damaged in any way during shipment.

If for any reason the unit should need to be returned in the future, this crate is the best way to ship it back to the manufacturer. Claims of damage due to freight handling can only be filed by you, the consignee, as **OGSI** shipping terms are Free On Board (FOB), North Tonawanda, NY USA. This means that once the equipment leaves our dock you are the owner of it. **OGSI** has no legal claim to make against any shipping company for damage.

At **OGSI**, we are committed to using shipping companies with good reputations for taking care in the handling of freight and providing service in the event of damage.

Warranty

Oxygen Generating Systems Intl., being a division of Audubon Machinery Corporation (hereinafter **OGSI**), provides a warranty on its products (the “Products”) against defects in material and workmanship, under normal use and operation, to the extent set forth in this Warranty.

THIS WARRANTY IS THE SOLE AND EXCLUSIVE WARRANTY OF **OGSI** WITH RESPECT TO THE PRODUCTS AND IS IN LIEU OF ALL OTHER WARRANTIES EXPRESSED OR IMPLIED ALL OF WHICH ARE HEREBY DISCLAIMED TO THE FULLEST EXTENT PERMITTED BY APPLICABLE LAW. WITHOUT LIMITING THE GENERALITY OF THE FOREGOING DISCLAIMER AND EXCEPT AS OTHERWISE SET FORTH IN THIS WARRANTY, **OGSI** DISCLAIMS ALL WARRANTIES OF MERCHANTABILITY WITH RESPECT TO THE PRODUCTS AND ALL WARRANTIES OF FITNESS FOR A PARTICULAR PURPOSE. THE WARRANTY OF **OGSI** AS SET FORTH HEREIN IS FOR THE BENEFIT OF THE ORIGINAL USER OF THE PRODUCTS AND IS NOT TRANSFERABLE WITHOUT THE PRIOR EXPRESS WRITTEN CONSENT OF **OGSI**.

The **OGSI** Warranty provides the following:

- 1) **OGSI** shall repair or replace the Products free of charge to the original user where defects in the material and/or workmanship are evident at the time of delivery. Such replacement of the Products does not include damages incurred in shipping the Products. If shipping damage is evident, the original user should contact the shipper immediately. **OGSI** will pay for shipping the Products to the original user as well as returning damaged/defective Products to **OGSI**. Once the Products are repaired, **OGSI** will ship the Products back to the original user and cover all costs incurred in shipping.
- 2) **OGSI** shall repair or replace the Products (excluding filter elements and sieve material) free of charge to the original user where defects in material and/or workmanship become evident between the time of delivery to the original user and one (1) year from the date of delivery to the original user. **OGSI** will pay for shipping the Products to the original user as well as returning damaged/defective Products to **OGSI**. Once the Products are repaired, **OGSI** will ship the Products back to the original user and cover all costs incurred in shipping. In no event shall **OGSI** have any responsibility or liability for the cost of labor for the removal of component parts or equipment that constitute part of the Products, packaging of the component parts or equipment that constitute part of the Products or the re-installation or replacement of the component parts or equipment that constitute part of the Products.
- 3) The warranty provided by **OGSI** to the original user covers parts and equipment specifically manufactured by **OGSI** and used as components or equipment that constitute part of the Products. The warranty on parts or equipment manufactured by third parties and included as part of the Products (*e.g., air dryers, air compressors, oxygen compressors, instrumentation, etc.*) is limited to the respective original warranties of such third parties.

Note: A *Return Authorization Number* must be obtained from **OGSI** prior to the return shipment of the Product or any component parts or equipment of the Products. The *Return Authorization Number* must be visibly written on the outside of the package of the

returned Products, component parts or equipment as applicable or **OGSI** will not accept the return.

Note: A *Credit Certificate* will be created for all Warranty Exchange transactions. **OGSI** will provide the *Credit Certificate* with an invoice at the time of shipment to the original user. The *Credit Certificate* must be included in the package to **OGSI** with the returned products within 30 days of the date of the invoice. Failure to return Warranty Exchange Products to **OGSI** within 30 days will make the Warranty Exchange process void and payment for Products will be billed and due on receipt.

Note: The warranties of **OGSI** as set forth herein shall also become null, void and not binding on **OGSI** if a defect or malfunction occurs in the Products or any part of the Products as a result of:

- a) A failure to provide the *Required Operating Conditions* for the Products
(See page 22)
- b) Repair, attempted repair, adjustment or servicing of the Products, or any component parts or equipment that constitutes part of the Products by anyone other than an authorized representative of **OGSI**. The authorized service representative must obtain prior approval from **OGSI**'s Service Manager before performing any warranty work.
- c) External Causes (e.g. flood, hurricane, tornado, fire, any natural disaster, or any event deemed an act of God).

Molecular Sieve Replacement:

The breakdown of the molecular sieve inside the generator (dusting of the sieve) only occurs if excess water/oil is entrained in the feed air stream. Under no circumstances is the molecular sieve covered under any warranty by **OGSI**. If sieve dusting occurs on your machine, check the air compressor, air dryer and filter elements.

Other Matters:

OGSI is not liable for any special, indirect, punitive, economic, incidental or consequential losses or damages including without limitation, loss of use, malfunction of **OGSI** products, replacement oxygen charges, delays or lost savings related to the Products or otherwise even if **OGSI** shall have been advised of the possibility of such potential losses or damages.

Limits of Liability

OGSI Oxygen Generator products shall not be used for breathable or medical oxygen applications, unless they are assembled with the appropriate support equipment, tested, and operated in compliance with either American, Canadian or ISO norms for hospital oxygen systems.

Safety Guidelines



Handling of Compressed Gas Cylinders

Many of the following procedures for the handling, storage, and utilization of compressed gas in cylinders are taken from material furnished by the Compressed Gas Association, which complies with **OSHA** standards.



Always ensure that compressed gas cylinders are securely strapped or chained in place to prevent tipping or falling. Do not store near elevators, stairs, or passageways.



Do not place cylinders in a position where they might become part of an electric circuit. When electric welding is taking place, precautions should be taken to prevent accidental grounding of cylinders, permitting them to be burned by electric welding arc.

If visual inspection indicates obvious damage, the cylinder should be returned to the supplier without any attempt at using the machine.

If cylinder leaks, other than normal venting, and the leak cannot be corrected by tightening a valve gland or packing nut, the valve should be closed and a tag attached stating that the cylinder is not serviceable. Remove the cylinder outdoors to a well-ventilated or open area, notify the supplier, and follow the supplier's instructions for the return of the cylinder.

Keep the cylinder valve closed at all times except when in active use. When removable caps are provided for valve protection, they should not be removed except for active use. Remember to replace removable caps when not in use.

Cylinders should not be dropped or permitted to strike each other or any other surface. Do not drag or slide cylinders; use a suitable hand truck, fork truck, roll platform or similar device, firmly securing the cylinders for transporting.

Do not store oxygen cylinders with flammable gas cylinders. Stored oxygen and fuel gas cylinders should be at least 20 ft apart; preferably separated by a fire resistant partition.

*For additional information refer to the CGA publications that can be found at <http://www.cganet.com>
See also ISO publication 10083 that can be found online at <http://www.iso.org>*



Operating

OGSI Oxygen Generators are self-contained systems for the production of high concentration oxygen. Although oxygen itself is not combustible, it can be very dangerous. It greatly accelerates the burning of combustible materials.



Precautions should be taken to avoid a fire in the area of the generator.



Smoking should not be permitted in the area where the generator is located.



All oxygen connections and hoses should be kept clean and free of grease, oil and other combustible materials.



Valves controlling oxygen flow should be opened and closed slowly to avoid the possibility of fires or explosions that can result from adiabatic compression.



Do not attempt to modify or enhance the performance of an oxygen generator in any way.

When bleeding a tank or line, stand clear and do not allow oxygen to embed itself within clothing. A spark could ignite the clothing violently.

Product Information



Features and Applications

The *OGSI* Model **OGS-20** extracts oxygen from the atmosphere using Pressure Swing Adsorption (PSA) technology. It concentrates oxygen up to **93%** ($\pm 3\%$) purity which can be applied in various ways.

Features

Easy to use

- Just connect to an electrical outlet, push the **ON/OFF** power switch to the **ON** position and set your desired pressure and flow.

Dependable

- Its internal air compressor, filtration system, Zeolite sieve, storage tank, and flow control system are designed for **24/7** operation.

Durable

- With oxygen-clean brass tubing and valves, the **OGS-20** can operate even in harsh environments.

Safe

- A built-in oxygen pressure regulator allows you to set the delivery pressure according to your needs. The compressor on the **OGS-20** has **0.33 Hp** and has a built-in safety relief valve to prevent excessive pressures. The **OGS-20** has a built-in pressure switch to maintain tank pressure between **75 psi (5.2 bar)** and **85 psi (5.9 bar)**.

Economical

- Oxygen is free! The **OGS-20** eliminates the unnecessary costs involved in transportation, storage and cylinder rental. The **OGS-20** uses less than **1.1 kW** of electricity to deliver up to **20 ft³** of oxygen per hour. This product is cost-effective and energy efficient.

Applications

The **OGS-20** can be used in various applications. A few examples are given below.

Hospitals and Clinics



Veterinary Centers



Biotechnology



Hyperbaric Oxygen Therapy (HBOT)



Nursing Homes



Waste and Water Treatment



Pressure Swing Adsorption (PSA) Technology

An **OGSI** Oxygen Generator is an on-site oxygen generating machine capable of producing oxygen on demand in accordance with your requirements. In effect, it separates the oxygen (21%) from the air it is provided and returns the nitrogen (78%) to the atmosphere through a waste gas muffler. The separation process employs a technology called **Pressure Swing Adsorption (PSA)**. At the heart of this technology is a material called Molecular Sieve (Zeolite). This sieve is an inert, ceramic-like material that is designed to adsorb nitrogen more readily than oxygen. Each of the two beds that make up the generator contains this sieve. The process is described below.

Stage 1

Compressed air is fed into the first molecular sieve bed. Nitrogen is trapped, while oxygen is allowed to flow through.




Stage 2

When the sieve in the first bed becomes full of nitrogen, the airflow is then directed into the second bed.




Stage 3

As the second bed separates the oxygen from the nitrogen, the first bed vents its nitrogen into the atmosphere.



Stage 4


Compressed air is once again fed into the first bed and the process is repeated continuously. A constant flow of oxygen is produced.



This air separation process is reliable and virtually maintenance-free. The molecular sieve will last indefinitely, as long as it does not become contaminated with water or oil vapors. This is why regular filter element replacement is crucial to trouble-free operation. The filter elements are inexpensive and require semi-annual maintenance.

External Components Drawing


Front View



1. **Oxygen Generator Pressure (10-21 psi)**
2. **Air Pressure Gauge (20-45 psi)**
3. **Hours Meter**
4. **Power Switch**
5. **Oxygen Outlet Regulator**
6. **Storage Tank**
7. **Oxygen Compressor Inlet Pressure Gauge**
8. **Door Latch with Key**
9. **Storage Tank Pressure Gauge**
10. **Caster Wheels (Only on Horizontal Tank Set-up)**


Side Views

Left



1. Exhaust Fan
2. Power Cord
3. Main System Reset
4. Inlet Fan
5. Outlet Valve

Right



1. Exhaust Fan
2. Air Compressor Reset
3. Inlet Fan

Vertical Model

Front View



Side Views




External Components Description

<p>Oxygen Generator Pressure Gauge</p>	<p>This gauge shows the pressure in the storage tank before the regulator. It is useful in detecting leaks in the system that could affect the performance. It should vary between 10 psi (0.7 bar) and 21 psi (1.4 bar) while the unit is operating.</p>
<p>Air Pressure Gauge</p>	<p>This gauge indicates the air pressure being delivered by the internal air compressor to the sieve beds. It should vary between 20-40 psi (1.4 - 2.8 bar) while the unit is running.</p>
<p>Hours Meter</p>	<p>The hours meter shows how long the unit has been operating. This helps indicate when service intervals are due.</p>
<p>Power Switch</p>	<p>This switch controls power to machine. It is lighted while machine switch is in the ON position.</p>
<p>Oxygen Compressor Inlet Pressure Gauge</p>	<p>This gauge indicates the pressure at which the oxygen is being fed into the oxygen compressor. The regulator can adjust the pressure. This should be set to a maximum pressure of 5 psi (0.3 bar). A higher pressure could damage the oxygen compressor.</p>
<p>Power Cord</p>	<p>The power cord used on 115 VAC/60 Hz electrical systems comes with a three-pronged ground fault protected plug. For 230 VAC, a plug of local configuration will need to be installed by the end-user.</p>
<p>Reset Buttons</p>	<p>The reset buttons are actually circuit breakers that open if there is an electrical overload in the system. The air compressor reset is on the right side and the main system reset is on the left side of the machine.</p>
<p>Oxygen (O₂ Outlet)</p>	<p>This fitting is a ‚B’ size oxygen adapter. It can be removed to expose a 1/8” female NPT pipe fitting.</p>
<p>Cooling Fan</p>	<p>The cooling fan is used to draw air into the unit and to remove heat from the compressor. The fan runs while the unit operates.</p>

Internal Components Drawing


Front View



- | | |
|----------------------------------|---------------------------------|
| 1. Valve Block | 10. Sieve Bed |
| 2. Pressure Regulator | 11. Storage Tank |
| 3. Circuit Board | 12. Sieve Bed |
| 4. Inlet Pre-filter | 13. Delay Timer |
| 5. Air Inlet Filter | 14. Oxygen Compressor Fuse |
| 6. HEPA Filter | 15. Terminal Block |
| 7. Air Compressor | 16. Oxygen Compressor |
| 8. Cooling Tube (Heat Exchanger) | 17. Pressure Switch |
| 9. Air Compressor Capacitor | 18. Oxygen Compressor Capacitor |

Internal Components Description

Valve Block	The valve block holds the main valves that control the direction of airflow in the machine. These are the feed and waste valves for each bed. They direct feed air to each bed during oxygen production and waste nitrogen through the muffler to regenerate the sieve. The cycle continues while the unit operates.
Pressure Regulator	The pressure regulator controls the pressure delivered to the oxygen compressor. It should be set in a way so that the pressure does not exceed 5 psi (0.3 bar) . Setting the pressure too high can cause damage to the oxygen compressor.
Circuit Board	The circuit board controls the operation of the flow controlling valves. While one valve coil is energized, the other is not.
Air Inlet Filter	The air filter keeps dust and dirt from entering the compressor and needs to be changed twice a year in normal environments to maintain the unit's performance. In especially dirty and oily areas, it should be changed more often. Four times a year is recommended.
Air Compressor	The air compressor supplies the feed air to the sieve beds. It is held in place by four bolted rubber feet and can be easily replaced when necessary. It should work as designed for a minimum of 10,000 hours and will last 20,000 hours in many cases.
Heat Exchanger	The heat exchanger runs in front of the cooling fan and delivers the feed air from the air compressor to the valve block. Using this proprietary tube design, significant air temperature reduction occurs before the air enters the sieve beds, improving performance.
Sieve Beds	These beds contain the molecular sieve that performs the air separation process. They are spring loaded to prevent settling and should not ever need to be opened. If the sieve becomes contaminated, the beds can be easily replaced.
Terminal Strip Assembly	The terminal strip distributes electrical power as required to the compressor and control components of the machine.
Oxygen Compressor	The oxygen compressor boosts the low pressure oxygen from the typical 5 psi (0.3 bar) up to 85 psi (5.9 bar) .
Oxygen Booster	The oxygen booster increases the low pressure oxygen to the desired storage pressure.
Oxygen Pressure Regulator	The regulator controls the oxygen delivery pressure level. Turning it clockwise increases the delivery pressure while turning it counter-clockwise decreases the delivery pressure. The oxygen pressure gauge will indicate the level set. To lock it into place, push down the adjustment knob.



Process Flow Description

The normal flow of air through the **OGS-20** unit is shown on the previous page in the Process Flow Schematic. Once the incoming air is filtered and compressed in the **OGS-20** unit, it is directed into one of the two (2) sieve beds. As the air enters the bed, the nitrogen is adsorbed by the sieve and the oxygen passes through as product gas to the storage tank. Each bed produces oxygen until the sieve in that bed is saturated with nitrogen. When this occurs, the feed airflow is directed to the other bed, which continues the production process. While the second bed is producing oxygen, the first bed is releasing into the atmosphere the nitrogen it adsorbed, under very low pressure through a waste gas muffler.

From the storage tank, the oxygen product gas passes through a factory set product orifice and into a receiver tank. This storage tank serves as a reservoir for the oxygen prior to entering the oxygen compressor. The oxygen product gas is then delivered to the oxygen compressor where it is compressed into the storage tank up to **85 psi (5.9 bar)**. The system will automatically de-energize when this pressure is reached.

Unit Specifications

Performance

Oxygen Volume	20 SCFH @ 12 psi 10 LPM or 0.5 Nm ³ /h @ 0.8 bar
Oxygen Pressure	Up to 85 psi (5.9 bar)
Oxygen Purity	93% (± 3%) [United States Pharmacopeia (USP) XXII oxygen 93% Monograph]
Oxygen Dew point	- 60° F (-51° C)
Feed Air Requirement	None, compressor included
Response Time	Approximately 2 minutes to attain maximum purity after initial start-up or extended shut-down

Physical

Oxygen Outlet Fitting	B Size oxygen adapter
Air Inlet Fitting	None
Sound Levels	68 dBA @ 1 m
Dimensions	
▪ <i>Horizontal Model</i>	40 x 17 x 46 in (W x D x H) 102 x 44 x 117 cm (W x D x H)
▪ <i>Vertical Model</i>	24 x 19 x 69 in (W x D x H) 61 x 48 x 175 cm (W x D x H)
Weight	195 lb (89 kg)

Power Requirement

▪ Standard (Domestic)	115 VAC, 60 Hz, Single Phase 10 A
▪ Optional (International)	230 VAC, 50/60 Hz, Single Phase, 5 A

Oxygen Flow Rate

20 SCFH @ 0 psi (0.5 Nm³/h @ 0 bar) Tank Pressure

14 SCFH @ 85 psi (0.4 Nm³/h @ 5.9 bar) Tank Pressure

Safety Precautions



It is very important that you read the precautions below and make yourself aware of the hazards of oxygen in general. While it can be handled and used very safely, it can also be mishandled or applied incorrectly causing dangerous situations.



Oxygen is a fire hazard. It can be very dangerous as it vigorously accelerates the burning of combustible materials. To avoid fire and/or the possibilities of an explosion, oil, grease or any other easily combustible materials must not be used on or near the oxygen generator. **DO NOT SMOKE NEAR THE UNIT.** The unit should be kept away from heat and flames. Individuals who have experience handling oxygen systems should become the designated operators of the oxygen generator within your facility.



In crucial applications, it is important to have a backup supply of oxygen since the generator does not come with any reserve storage tank and requires electrical power to operate. ***Therefore, during power outages oxygen will not be produced.***

Do not use extension cords to bring power to the generator. The current drawn into the unit is high and could overheat some extension cords. It is also important to use only a properly grounded outlet.

High pressure oxygen may present a hazard. Always follow proper operating procedures, and ***open valves slowly.*** Rapid pressurization may result in personal injury. Safety glasses and hearing protection are required when venting oxygen under high pressure.

Ensure that the oxygen outlet stream is not directed toward anyone's clothing. Oxygen will embed itself in the material and one spark or hot ash from a cigarette could ignite the clothing vigorously.



Pre-Installation

Before installing the *OGSI* Oxygen Generator, it is necessary to consider the location, space available and power supply for the generator.

1) Locating the **OGS-20**:

- The oxygen generator should be located in an area that is indoors and remains between **40°F (5°C)** and **100°F (38°C)**. **Setting the machine outdoors or in an area that is not normally within this temperature range will void the *OGSI* Warranty.**
- There should also be a distance of at least **8 in (20 cm)** between the unit and any side wall in the room that it will be located. This is to ensure that airflow into the machine through the cooling fans is not restricted.

2) Space Available for the **OGS-20**:

- If the **OGS-20** unit is going to be set up in a room that is small, (less than **1000 ft³** or **28.3 m³**), that room should be well ventilated (at least **8** air changes in the room per hour). The generator will be discharging nitrogen into the atmosphere of the room and a nitrogen build up could be dangerous to people entering the room. If the generator is placed in a small closet, the air in that closet will become enriched with nitrogen. As the generator continues to run, it would become more and more difficult for it to separate the oxygen from the air because oxygen will make up a smaller and smaller fraction of the air that is fed into the generator.

3) Power Supply for the **OGS-20**:

- The oxygen generator should be positioned within **8 ft (2.2 m)** of the electrical outlet that will power it. The reason for this is that the motor draws a large current during the first few seconds of start-up. **It is also very important for this reason NOT to use any extension cords with the unit.** They could overheat and melt, possibly causing a fire.



Required Operating Conditions

Location of Machine:

The standard oxygen generator is intended for use indoors in a commercial or light industrial setting. The enclosure meets **NEMA 12** protection guidelines, which provides a degree of protection against dust, falling dirt and non-corrosive liquids.

Feed Air/Ambient Air Quality:

The life of any PSA oxygen generator is directly related to the air quality that is fed into it. Hot, humid, dirty, oily air deteriorates and degrades the performance of the molecular sieve. In order to preserve the effectiveness and extend the life of the generator, precautions must be taken to ensure that the air provided is cool, dry, clean and oil-free. Changing the inlet air filter is a simple and easy way to provide the unit with some protection. It is advisable to set up the unit in an air-conditioned or a well-ventilated area. The room should also be free of toxic gases and high concentrations of hydrocarbons, especially carbon monoxide. Humid, oily areas should be avoided as installation sites as much as possible.

Ambient Air Temperature:

The machine is designed for use over a temperature range of **40°F to 100°F (5°C to 38°C)**. Since hot air has the ability to hold much more water in the form of humidity than cool air, operating the units in hot areas will reduce the effective life of the molecular sieve.


Note: Operation outside of this temperature range will not be warranted by **OGSI**.

Electrical Power:

On U.S. models, the power for the control circuitry of the oxygen generator is a single-phase electrical supply of **115 VAC** and about **10 A** at a frequency of **60 Hz**. This equates to approximately **1200 W** of power. It is required that a **15 A** circuit be dedicated to each **OGS-20** unit. Additionally, the unit must be connected to this circuit using only the supplied power cord, and without additional extension cords.

Positioning:

The unit must be operated in an upright position only, with no obstruction blocking airflow around the unit.



Set-up & Installation

Although every **OGS-20** unit is thoroughly tested and checked before it is shipped from our facility, the following checks are necessary to ensure that none of the internal components have been damaged in shipment. This check should take less than five minutes to perform. (Refer to '**Initial Inspection**' on Page 2 before reading the instructions below)

Make a visual inspection of the machine and make sure all parts are properly attached. (Refer to '**Components**' section)



Connect the unit into an electrical outlet. A receptacle plug of local configuration will need to be attached first if the machine has been shipped outside North America.



Push the **ON/OFF** green lighted switch to the **ON** position and make sure that the green light is illuminated.



Listen for the sound of the compressor to start operating, if you do not hear it within a few seconds, shut the machine down immediately and call **OGSI** for assistance.

The oxygen storage tank pressure gauge should indicate a pressure increase after approximately **15** minutes. If this does not occur, check to make sure that none of the hose connections have come loose. Call **OGSI Technical Service Department** at **(800) 414-6474** (toll free number in USA and Canada) or **(716) 564-5165** if no loose connections are found and trouble persists.



Operating Instructions

Start-up

Once the system has been installed in accordance with the set-up and installation instructions, it may be operated. The following steps should provide some direction. Please keep in mind that this system is not designed for use as a medical oxygen concentrator.

Connect the oxygen outlet to the application.



After connecting it to an electrical outlet and pushing the switch on the machine to the **ON** position, wait for **2** minutes for the unit to come up to maximum purity.

If this is the initial start-up, you may have to operate the machine and drain the tank several times before all of the low purity gas has been eliminated in the tank.

Begin using the oxygen.

Shut-down



To shut off the machine, push the **ON/OFF** power switch to the **OFF** position. The light should go out on the switch and the compressor noise should quickly fade.

Troubleshooting Guide

Problem	Sign	Cause	Solution
Dusting of Sieve Beds	White powder visible in the machine or very high pressure levels	<ul style="list-style-type: none"> • High pressuring of machine • Beds contaminated with moisture 	<ul style="list-style-type: none"> • Replace sieve beds. • Move the machine to dry environment.
Machine not starting	Not Applicable	<ul style="list-style-type: none"> • Machine not plugged in • Machine not turned on • No power to the machine • Circuit breaker has tripped • Compressor under pressure • Loose wire 	<ul style="list-style-type: none"> • Ensure that machine is plugged in. • Ensure that switch is in the ON position. • Ensure that there is power supply to the machine. • Push in the reset button on the right hand side of the cabinet. • Remove the head pressure that exists in the compressor outlet stream. • Check that all wiring connections are secure.
Valves Sticking	Pressure levels too high	Dusting of sieve or machine filled with dirt and dust due to filters not being replaced	<ul style="list-style-type: none"> • Remove valve block from machine and clean valves and spools completely. • Replace air filter.
Pressure Switch not Working	Machine not turning ON/OFF at target pressures	Faulty switch	Remove switch and return for replacement.



Warning Signs

Low Oxygen Pressure

This may be a result of a leak in the system.
Use a leak testing solution to locate and repair any air leaks.

The machine has run for 30 minutes and purity has not yet been reached

This may be a result of a leak in the system.
Use a leak testing solution to locate and repair any air leaks.

Oxygen purity has fallen below acceptable limits

This may be an indication of a leak within the system.
Use a leak testing solution to locate and repair any leaks.

Preventive Maintenance

Air Filter Element Replacement:

The air filter element provided with the **OGS-20** must be replaced every **six (6)** months on an average. This element helps to maintain the quality of the feed air supply and preserve the molecular sieve inside the oxygen generators.

Failure to replace the filter element on schedule will result in the warranty becoming invalid.

Cabinet & Power Cord:

The cabinet and power cord should be occasionally wiped down with a sponge or clean rag and some soapy water. Avoid the use of ammonia or other strong chemical based cleaning solvents. This prevents dust and dirt from building up on the machine.

Air Compressor:

You should consider your air compressor an important part of your oxygen generating system. In addition to changing the air filter element, maintenance is relatively simple. The fans on either end should remain free of debris/dust. The air compressor should last **five (5) or six (6) years** or longer under normal operating conditions. Eventually, however, it will need to be rebuilt or replaced. Oxygen purity and flow rate along with feed air pressure delivered to the sieve beds will all be indicators that the air compressor has expended its life. Replacement in the field is possible, but returning the unit to **OGSI** or an authorized service center is recommended.

Technical Service Assistance

It is our intention to provide complete customer satisfaction. This manual is one way in which we hope to provide you with technical assistance.

If you do not find what you need in this manual or you have other questions about this equipment, please feel free to contact us directly. We look forward to serving your oxygen needs and invite your inquiries. We will respond to you as promptly as possible.

You can reach **OGSI** through the following means:

- **By Telephone (Within the United States):**
(800) 414-6474 - Our toll free number (Within USA only)
(716) 564-5165 - Our direct number
- **By Telephone (Outside the United States):**
Your local International Access Code (usually **0** or **00**), followed by
The Country Code for the U.S. which is **(1)**, followed by
Our Area Code and Number **(716) 564-5165**
- **By Automated Voicemail:**
(716) 564-5165
- **By Fax (Within or outside the United States):**
(716) 564-5173
- **By E-Mail or Website:**
ogsimail@ogsi.com
<http://www.ogsi.com>
- **By Mail:**
OGSI
814 Wurlitzer Drive
North Tonawanda
New York 14120 USA
- **By UPS, FedEx or Common Carrier: (Address to return shipments)**
OGSI
814 Wurlitzer Drive
North Tonawanda
New York 14120 USA

*Technical service personnel are available from 8:00 AM to 5:00 PM EST (GMT - 5).
We also have a list of Distributors and Authorized Service Agents available upon request.*

Customer Satisfaction Survey

Help us serve you better. Please take our Customer Satisfaction Survey at www.ogsi.com

Appendix

Spare Parts List

<u>PART NAME</u>	<u>PART NUMBER</u>	<u>QUANTITY</u>
Power Cord 12-3	1890001.123	1
Strain Relief for Power Cord	1820018.E01	1
Cord Set for Fan (115/230 VAC) 24 in	1890003.001	2
Cord Set for Fan (115/230 VAC) 48 in	1890003-002	2
Hours Meter 115 VAC	1870002.002	1
Hours Meter 230 VAC	1870002.003	1
On-Off Lighted Switch	1840001.004	1
Timer 115/230 VAC	1850001.002	1
7 A Thermal O/L button	1830002.001	1
10 A Thermal O/L button	1830002-010	1
2.5 A Fuse	1830001-002	1
85 psi Pressure Switch	1900001-B85	1
Valve Wire Harness (each) 115 VAC	1880011.002	2
Valve Wire Harness (each) 230 VAC	1880011.003	2
3-prong 115 V Plug End	1820014-305	1
Delay Relay Timer	1850005-002	1
Solenoid Valve Assembly 115 VAC/230 VAC	7020005.001	1
Inline Check Valves	1530001.B01	2
1 ¹ / ₂ ", 0-30 psi Dial Gauge, Oxygen Pressure	2190001.LB3	1
1 ¹ / ₂ ", 0-60 psi Dial Gauge, Air Pressure	2190001.LB2	1
1 ¹ / ₂ ", 0-15 psi Dial Gauge, Oxygen Pressure	2190001-LB1	1
2", 0-100 psi Dial Gauge, Oxygen Pressure	2190002-NC1	1
Oxygen Receiver Tank Assembly	7050004.001	1
Oxygen Pressure Regulator	2150002.120	1

1/4" Safety Relief Valve-55#	1540001.C01	1
Compressor Assembly (115 VAC, 60 Hz)	7030004.001	1
Compressor Assembly (230 VAC, 50 Hz)	7030004.002	1
Thomas Compressor Rebuild Kit	2114001.T01	1
Gas Compressor Rebuild Kit for 72R Series	TBD	1
Air Compressor Rubber Mounts	1460001.CC1	4
Oxygen Compressor Rubber Mounts	1460001-AC1	3
Enclosure to Tank Rubber Mounts	1460001-006	4
115 V Oxygen Compressor	2115001-007	1
230 V Oxygen Compressor	21200BU-230	1
1/4" NPT MXF Check Valve	1530001-C03	1
1/4" NPT N/O Valve 115 V	1510009-C01	2
1/4" NPT N/O Valve 230 V	1510009-C02	2
1/4" Green Oxygen Tubing - Per Foot	2210004.C01	3.5
3/8" Poly Tubing - Per Foot	2210003.E02	3
Purge Loop Assembly	7040008.001	1
Inlet Air Filter (Change every 6 months)	2160001.C01	2
Black Filter for Quiet Muffler Option	2160001.C02	2
Inlet Fan 115 V	2140001.001	1
Inlet Fan 230 V	2140001.002	1
HEPA filter	2160001-04	1
Replacement Set of Sieve Beds	7060003.001	1
Manual-Available Free on Website	9000000.010	1

Oxygen Cleaning Procedure

Scope

This procedure sets forth the cleaning requirements for parts that are used in the construction of **OGSI** oxygen systems and are in the gaseous oxygen product stream including but not limited to valves, tubing, fittings, manifolds and pipes.

Objective

The objective of this procedure is to provide personnel with clear directions and an understanding of how parts are to be cleaned and why that is important. This document is based on guidelines provided in publication **CGA G-4.1-2009** which is produced by the Compressed Gas Association (CGA) and is intended to ensure that our internal procedure is compliant with that publication.

Safety

Harmful contamination such as grease, dirt, oil, dust, solvents, weld slag, sand, rust and previously applied thread sealants on parts that come into contact with oxygen can cause a combustion reaction resulting in system degradation or failure or worse, a hazard to nearby personnel. Care needs to be taken in the cleaning and handling of components used in oxygen service to prevent any contamination related failure.


While the **CGA G-4.1-2009** standard makes allowance for cleaning parts using caustic agents, acids or solvents, the **OGSI** procedure will use only mechanical (soaking, wire brushing or grinding) means for pre-cleaning and hot water cleaning with aqueous detergents for final cleaning. This is done to reduce any chemical exposure risk to personnel and to eliminate the additional steps needed to remove these cleaning agents from the parts themselves.

Training

Personnel involved in the cleaning and preparation of parts used in oxygen service should be trained in these cleaning procedures and be familiar with this document.

Process Flow Chart

The flow chart below describes oxygen cleaning and parts handling process.



Parts Received and Initial Inspection

Upon determining which parts need to be cleaned, the technician needs to perform an initial visual inspection (under white light). Check for the presence of visible residue on the

parts including but not limited to oil, grease, dirt, dust, rust, weld slag or pre-existing thread sealant among others. For parts that have an internal cavity that is not directly observable by the naked eye, a lint free cloth that is first soaked in water can be inserted into the part and withdrawn for evidence of contamination. No part failing inspection shall be used in any assembly.

Pre-Cleaning

Pre-cleaning methods include soaking parts in a water based solution with an aqueous detergent, using a wire brush or thread pick, holding it under a wire brush grinding wheel or simply wiping it down with a clean rag. Upon completion of pre-cleaning, the part should be clear of any visible contamination and ready for final cleaning.

Final Cleaning

Final cleaning involves placing the parts in the parts washing machine, adding an appropriate amount of detergent and running them through the cleaning cycle. Consideration shall be given to the size, shape and number of parts to be cleaned at one time to ensure that the system is not overloaded or its function impaired. The cleaning temperature inside the washer shall be **120°F** to **140°F** and the detergent to be used shall be Cascade™. This detergent has a flash point above **105°F** but it does not sustain combustion and there are no exposure controls for it. Parts can be removed from the washer once the drying cycle is complete.

Inspection

Upon completion of the final cleaning cycle, all parts should be removed from the parts washing machine and inspected for any residual contamination. The item shall be observed to confirm the absence of any contaminants including any oil, grease, detergent, moisture, lint, or other foreign materials. If any material remains on the part after the final cleaning cycle, the part shall be returned for a second round of pre-cleaning and final cleaning.

Packaging

Once a part or assembly has been cleaned for oxygen service, it should be protected to prevent recontamination if it will be put into storage. Small to medium sized parts should be packaged in plastic bags. Larger assemblies should be bubble-wrapped or wrapped in foam material and then moved on to final packaging in boxes and/or crates.

Labeling

Once a part or an assembly has been cleaned and packaged for oxygen service, it should be labeled per the customer's instructions, but at a minimum;

- contain the statement "**Cleaned for Oxygen Service**"
- contain the date of cleaning or packaging

References

The following publications were referenced in the creation of this document.

- CGA G-4.1-2009, *Cleaning Equipment for Oxygen Service*, Compressed Gas Association, Inc., 4221 Walney Road, 5th Floor, Chantilly, VA 20151. www.cganet.com
- *Oxygen Cleaning Procedure* Rev. L (8/05), RIX Industries, Inc., 4900 Industrial Way, Benicia, CA 94510. www.rixindustries.com

Air Changes by Room Size/Machine Size

Air Changes Required in a Room Per Hour for All Models

Model Number	Room Volume in Cubic Feet (ft ³)										
	1000	2000	3000	4000	5000	6000	7000	8000	9000	10000	12500
OG-15	5	2.5	2	1.5	1	1	1	1	1	1	1
OG-20	8	4	2.5	2	2	1.5	1	1	1	1	1
OGS-20	8	4	2.5	2	2	1.5	1	1	1	1	1
OG-25	10	5	4	2.5	2.5	2	1.5	1	1	1	1
OG-50	20	10	7.5	5	5	4	3	2.5	2	2	1.5
OG-100	NR	20	15	10	9	8	7	5	4	4	3
OG-175	NR	25	18	12.5	11	10	8	6	5	5	4
OG-250	NR	30	22.5	15	13	11	9	7.5	7	6	5
OG-375	NR	NR	30	27	22.5	18	15	13	11	8	7
OG-500	NR	NR	NR	30	27	22.5	18	15	13	11	8
OG-650	NR	NR	NR	NR	30	27	22.5	18	15	13	11
OG-750	NR	NR	NR	NR	NR	30	27	22.5	18	16	13
OG-1000	NR	NR	NR	NR	NR	NR	NR	30	26	22	17
OG-1250	NR	NR	NR	NR	NR	NR	NR	NR	NR	30	24
OG-1500	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	30
CFP-15+/15M	5	2.5	2	1.5	1	1	1	1	1	1	1
MOGS-100	NR	20	15	10	9	8	7	5	4	4	3

Notes:

1. **NR** means that the models indicated are not recommended for rooms of this size.
2. For air changes requirements for models **OG-2000** and above, please contact **OGSI**.

Units of Measurement

lb	U.S. Pound
hp	Horsepower
psi	Pound-force per Square Inch
kW	Kilowatt
kWh	Kilowatt Hour
ft³	Cubic Feet
VAC	Volts Alternating Current
Hz	Hertz
SCFH	Standard Cubic Foot per Hour
SCFM	Standard Cubic Foot per Minute
LPM	Liter Per Minute
1 bar	1.45 x 10 ¹ psi
dBA	Decibel (A scale)
A	Ampere
W	Watt
°C	Degree Celsius/Centigrade
°F	Degree Fahrenheit

